

島根原子力情報伝送システムの伝送計画（2020年5月）

□ テレメータ変動期間  
 ■ テレメータ停止期間

	5月																																
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
2号機発電機出力	[変動]																																
No. 1モタリングポスト	[変動]																																
No. 2モタリングポスト	[変動]																																
No. 3モタリングポスト	[変動]																																
No. 4モタリングポスト	[変動]																																
No. 5モタリングポスト	[変動]																																
No. 6モタリングポスト	[変動]																																
1号機放水路水モタ	[変動]																				④5/20 14:30~15:30												
2号機放水路水モタ	[変動]							⑤5/8 9:00~17:00			[変動]				⑤5/12 13:00~18:00		[変動]				②5/14 9:00~17:00			[変動]									
1号機排気筒モタ	[変動]													③5/14 9:00~17:00				[変動]															
2号機排気筒モタ	[変動]							①5/7 10:00~11:00			[変動]				②5/14 9:00~17:00				[変動]														
1号機タービン排気筒モタ	[変動]													③5/14 9:00~17:00				[変動]															
2号機非常用ガス処理系モタ	[変動]													②5/14 9:00~17:00				[変動]															
風向	[変動]																												⑥5/28 12:00~13:00				
風速	[変動]																												⑥5/28 12:00~13:00				

[計画変更] (変更箇所については朱記表示)

⑥風向・風速計用電源切替に伴う伝送停止 (5/28)

[作業内容]

① 2号機ディーゼル燃料貯蔵タンク室通気管他改造工事におけるノイズチェックに伴う伝送停止 (5/7)

② 2号機電気・計装盤等の打振試験に伴う伝送停止 (5/14)

③ 2号機ケーブル処理室耐火障壁設置工事のうちケーブル敷設工事に伴う伝送停止 (5/14)

④ 2号機ケーブル処理室固定式消火設備干渉対策工事におけるノイズチェックに伴う伝送停止 (5/20)

⑤ 2号機放水路水モニタ点検に伴う伝送停止 (5/8, 5/12)

以上